

DRINKING WATER NOTICE

Failure to Comply with the Requirements for Corrosion Treatment

Portage County Water Resources failed to Comply with the Requirements for Corrosion Treatment

You are being notified because Aqua Ohio – Aurora East public water system purchases your water from Portage County Water Resources.

Portage County Water Resources is required to monitor your drinking water for specific parameters on a regular basis. Results of regular monitoring are an indicator of whether or not **Portage County Water Resources** drinking water meets health standards. **Portage County Water Resources** is required to maintain a minimum orthophosphate level of 1.5 mg/L to ensure optimal corrosion control is provided. For the period of November and December 2017, **Portage County Water Resources** did not maintain the required orthophosphate level, and therefore cannot be sure that optimal corrosion control was provided.

What should I do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective action.

What is being done?

Upon being notified of this violation, **Portage County Water Resources** water supply was required to have the drinking water analyzed for the above mentioned parameters. **Portage County Water Resources** (the water supplier) will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact Aqua Ohio's Customer Service at 877.987.2782.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH6700512

Date Distributed: 2/14/2018